ਵੱਲੋਂ

ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ,
ਪ੍ਰਾਂਤਕ ਉਪਮੰਡਲ, ਲੋ.ਨਿ.ਵਿ ਭ ਤੇ ਮ ਸ਼ਾਖਾ,
ਸੁਨਾਮ

ਵੱਲ

ਪ੍ਰਿੰਸੀਪਲ,
ਪੈਰਾਮਾਉਂਟ ਪਬਲਿਕ ਸਕੂਲ
ਜੀਮਾ।

ਨੰਬਰ:59 ਮਿਤੀ: 01.06.2026

ਵਿਸ਼ਾ:- ਸਾਲ 2026-27 ਦੇ ਲਈ ਬਿਲਡਿੰਗ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਜਾਰੀ ਕਰਨ ਸਬੰਧੀ।

ਉਪਰੋਕਤ ਵਿਸ਼ੇ ਸਬੰਧੀ ਪ੍ਰਾਪਤ ਹੋਇਆ ਕੇਸ ਸਬੰਧਿਤ ਜੇ.ਈ. ਵੱਲੋਂ ਲੋੜੀਂਦੀ ਇੰਨਸਪੈਕਸ਼ਨ ਕਰਨ ਉਪਰੰਤ ਸਮੇਤ ਸਰਟੀਫਿਕੇਟ ਆਪ ਜੀ ਨੂੰ ਅਗਲੇਰੀ ਯੋਗ ਕਾਰਵਾਈ ਹਿੱਤ ਭੇਜਿਆ ਜਾਂਦਾ ਹੈ। ਲੋੜੀਂਦੀ ਇੰਨਸਪੈਕਸ਼ਨ ਫੀਸ ਆਪ ਵੱਲੋਂ ਆਨਲਾਇਨ ਬਾਬਤ ਰੁਪਏ 15000/- (ਪੰਦਰਾਂ ਹਜ਼ਾਰ ਰੁਪਏ ਸਿਰਫ) ਈ ਚਲਾਨ ਰਸੀਦ ਨੰ. **23447947** ਮਿਤੀ: 14.05.2026 ਰਾਹੀਂ ਜਮਾਂ ਕਰਵਾ ਦਿੱਤੀ ਗਈ ਹੈ।

ਇਸ ਤੋਂ ਇਲਾਵਾ ਆਪ ਵੱਲੋਂ ਨਾਲ ਨੱਥੀ ਕੀਤਾ ਗਿਆ ਫਾਇਰ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ, ਜਿਸ ਦੀ ਜਾਰੀ ਕਰਨ ਦੀ ਮਿਤੀ: 18.11.2025 ਹੈ, ਜੋ ਕਿ ਮਿਤੀ 17.11.2028 ਤੱਕ ਵੈਲਿਡ ਹੈ। ਜੇਕਰ ਆਪ ਦੀ ਸੰਸਥਾ ਵੱਲੋਂ ਭਵਿੱਖ ਵਿੱਚ ਉਕਤ ਸ਼ਰਤਾਂ ਦੀ ਉਲੰਘਣਾ ਕੀਤੀ ਜਾਂਦੀ ਹੈ ਤਾਂ ਇਹ ਸਰਟੀਫਿਕੇਟ ਉਸੇ ਮਿਤੀ ਤੋਂ ਰੱਦ ਸਮਝਿਆ ਜਾਵੇਗਾ।

ਨੱਥੀ:- ਸਰਟੀਫਿਕੇਟ

ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ,
ਪ੍ਰਾਂਤਕ ਉਪਮੰਡਲ, ਲੋ.ਨਿ.ਵਿ ਭ ਤੇ ਮ ਸ਼ਾਖਾ,
ਸੁਨਾਮ

ਪਿੱਠ ਅੰਕਣ ਨੰ. ਮਿਤੀ:

ਉਪਰੋਕਤ ਦਾ ਉਤਾਰਾ ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ, ਪ੍ਰਾਂਤਕ ਮੰਡਲ ਭ ਤੇ ਮ ਸ਼ਾਖਾ ਸੰਗਰੂਰ ਜੀ ਨੂੰ ਉਹਨਾਂ ਦੇ ਪੱਤਰ ਨੰ. 627 ਮਿਤੀ: 21.04.2026 ਦੇ ਸਬੰਧ ਵਿੱਚ ਸੂਚਨਾਂ ਹਿੱਤ ਭੇਜਿਆ ਜਾਂਦਾ ਹੈ।

ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ,
ਪ੍ਰਾਂਤਕ ਉਪਮੰਡਲ, ਲੋ.ਨਿ.ਵਿ ਭ ਤੇ ਮ ਸ਼ਾਖਾ,
ਸੁਨਾਮ

Scanned with CamScanner

Part-II

Building Safety Report

Name of School: Paramount Public School, Cheema. Distt. Sangrur.

Sh. Shubham Goyal (Junior Engineer) has visited the above mentioned school on dated 13.05.2026 and on his visual inspection: the building seems to be safe subject to the following observation & conditions.

a) Parameters to check the stability and safety of building as Architectural Drawings, Bearing capacity, Foundation detail, Structural Drawings, Technical Specifications, Test Reports of Material used, Quality Control reports and certificate from the Engineer in-Charge for construction are not available.

b) In case any addition, alteration or expansion and modification to this building are done certificate may be obtained after the completion from the undersigned.

c) In case the building is affected by flood or if there is any settlement of walls/ foundation or sagging of roofs etc. immediate inspection of the undersigned be arranged to check stability and safety of the building.

d) This Certificate holds validity only with valid Fire Safety Certificate. A separate certificate regarding Fire Fighting should be obtained from the competent Authority & **it will be your personal responsibility to extend the period of the said fire safety certificate upto and after extending the period, this office should be informed , failing which the building safety certificate issued by this office will be considered cancelled with immediate effect.**

e) A separate certificate regarding Electrical works should be obtained from the competent Authority.

f) The owner of the building / Management is fully responsible regarding safety of the building from all angles in spite of the report.

g) The covered area of the building is As per Drawings Sft.

h) The report is not valid for legal purpose.

i) The building visually seems safe to occupy for normal use to **One Year, upto** 31-03-2027

(Shubham Goyal)
J.E

Sub Divisional Engineer
Provincial Sub Div. PWD, B&R
Sunam

Scanned with CamScanner